

Table 1 - Water Sample Results
Lead - Location

Project Name: Herkimer Central School District

B&L Project No.: 899.115.001

Sample Date: 12/16/2016 - High School

Location	Sample ID	Approx. Time (hh:mm)	Sample Analysis	Results (µg/l)	NYS SED/EPA Action Level* (µg/l)	Comments	
Rm 172	HHS172BX-1	07:25	Lead	7.1000	15.000	First draw	Left Sink
	HHS172BX-2	07:26	Lead	7.4000	15.000	Second draw	
			Lead		15.000	Third Draw	
Rm 172	HHS172BX-3	07:28	Lead	5.0000	15.000	First draw	Right Sink
			Lead		15.000	Second draw	
			Lead		15.000	Third Draw	
			Lead		15.000	First draw	
			Lead		15.000	Second draw	
			Lead		15.000	Third Draw	
			Lead		15.000	First draw	
			Lead		15.000	Second draw	
			Lead		15.000	Third Draw	
			Lead		15.000	First draw	
			Lead		15.000	Second draw	
			Lead		15.000	Third Draw	
			Lead		15.000	First draw	
			Lead		15.000	Second draw	
			Lead		15.000	Third Draw	
			Lead		15.000	First draw	
			Lead		15.000	Second draw	
			Lead		15.000	Third Draw	

< - less than detectable level

* - NYS SED/EPA Action Level for Schools

ug/l - micrograms per liter of water

bold - at or exceeds an action level